

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50419939

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
K.S.

Unser Zeichen *Our Reference*
01-JJX-50051571 012

Ausstellungsdatum *Date of Issue*
16.11.2018
(day/mo/yr)

Genehmigungsinhaber *License Holder*
Helukabel Singapore Pte. Ltd.
159 Sin Ming Road,
#02-01 Amtech Building 575625
Singapore

Fertigungsstätte *Manufacturing Plant*
030-0000436611

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1419062801

Geprüft nach *Tested acc. to*
EN 50618:2014

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Cables (Electric Cables for Photovoltaic Systems)

Type Designation	: H1Z2Z2-K 1X2,5...35mm ² HELUKABEL	11
Rated Voltage	: DC 1,5kV AC 1,0/1,0kV	
Ambient Temperature	: -40°C to +90°C	
Max. Temperature at Conductor	: 120°C	

11

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

