

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50419940

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
K.S.

Unser Zeichen *Our Reference*  
01-JJX-50136465 006

Ausstellungsdatum *Date of Issue*  
16.11.2018 (day/mo/yr)

Genehmigungsinhaber *License Holder*  
Helukabel Singapore Pte. Ltd.  
159 Sin Ming Road,  
#02-01 Amtech Building 575625  
Singapore

Fertigungsstätte *Manufacturing Plant*  
030-0000436611

## Prüfzeichen *Test Mark*



Type Approved  
Safety  
Regular Production  
Surveillance

www.tuv.com  
ID 1419062802

Geprüft nach *Tested acc. to*  
IEC 62930:2017

Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)*

Lizenzentgelte - Einheit  
*License Fee - Unit*

Cable (Electric Cables for Photovoltaic Systems)

Type Designation	: 62930 IEC 131 1X2,5...35mm <sup>2</sup> HALOGEN FREE LOW SMOKE HELUKABEL	11
Rated Voltage	: DC 1,5kV	
Max. Storage Temperature	: +45°C	
Min. Temperature for Installation and Handling:	: -25°C	
Max. Temperature at Conductor	: 120°C	

11

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
*This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.*

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com  
Fax: +49 221 806-3935 <http://www.tuv.com/safety>

Zertifizierungsstelle



Jie Zhang